

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1273:116 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Digital Security Control, 95 Bridgeland Ave., Toronto, Ontario, Canada M6A 1Y7*
Contact: Dan Nita (905) 760-3000 FAX (905) 760-3020

DESIGN: Models P4350, P4350R, PS4350, PS4350R, P5350, P5350R, PS5350 and PS5350R external battery cabinets with charger. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name (DSC) or "Partner", model number, electrical rating and UL label.

APPROVAL: Listed as battery cabinets with charger for use with listee's separately listed compatible fire alarm control units.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**